DEPARTMENT OF PUBLIC WORKS
SUMMARY OF OPERATIONS
JULY 2014

Water System

- Repaired leaks at 261 West 290 South (split poly service line), 200 West 460 North (broken two-inch valve), 400 East 35 South broken PVC), 385 East 1100 South (split poly service line), and 752 East Mesa Vista (eight-inch bell leaking)
- Replaced eight-inch valve at 400 East Center
- Installed seven new meters
- Replaced fourteen meters, fourteen ERT's, and fourteen registers
- Completed twenty-five work orders
- Completed meter reading, monthly vault and weekly tank inspections, and water samples

Sewer System

- Flushed sewer main on 685 South
- Weekly lift station maintenance

Street Maintenance

- Used four tons of road base and three tons of asphalt repairing streets due to water leaks
- Used six tons of road base and four tons of asphalt repairing shoulders and streets
- Used six cubic yards of concrete repairing sidewalks and manhole collars





- Repaired/replaced one street sign
- Logged forty hours sweeping streets covering fifty-eight lane miles

Storm Drain

- Cleaned various storm drain inlets
- Weekly public works facility storm water inspections

Vegetation Control

- Sprayed two-hundred gallons of herbicide in right-of-ways in various locations
- Cleared weeds from right-of-ways in various locations

Utility Locating (Blue Stakes)


- Received and completed sixty-four locate requests

Training

- Weekly in-house safety meetings

Miscellaneous

- Used sixty tons of road base for a drying bed for the street sweepings
- Assisted with fleet maintenance as needed
- Performed inspections on active projects
- Saturday dumpsters
- Staff and department meetings



5 YEAR MONTHLY WATER USAGE COMPARISON

