DEPARTMENT OF PUBLIC WORKS
SUMMARY OF OPERATIONS
JULY 2015

Water System

- Completed 24 utility work orders
- Installed five new 5/8 meters this month
- Changed out six faulty registers
- Changed out ten faulty ERTs
- Changed out three faulty 5/8 meters
- Changed out four faulty 2inch meters to high performance E- series meters
- Completed meter reading monthly vault and tank inspections and water samples
- Flow tested and flushed approximately 220 fire hydrants
- Relocated and replaced one fire hydrant at 117 East 200 South
- Repaired water service leak at 465N 300W.
- Repaired water service leak in Eagle Rock #76

Sewer System

- Cleaned 18,320 feet of sewer main
- Weekly lift station maintenance

Street Maintenance

- Used approximately eight tons of road base to repair shoulders and repair streets.
- Used approximately two tons of asphalt to repair shoulders and repair streets.
- Used approximately 1.25 yards of concrete to replace damaged sidewalk.
- Used approximately twelve tons of four inch lava rock to repair shoulders in various locations throughout the city.
- Reshaped and graded dirt roads on 600 West from 200 North to 450 North.
- Repaired / Replaced eleven street signs this month.
- Logged 48 hours of sweeping streets covering 110 lane miles.
- Hauled 2 loads of sweeper tailings to the Landfill.

Storm Drain

- Cleaned storm grates and removed sediment and debris from culvert inlets.
- Weekly Public Works Facility Storm Water Inspections.

Vegetation Control

- Cleared weeds and trash from right of ways in various locations throughout the city.
- Trimmed bushes and tree branches in various locations throughout the city.
- Sprayed approximately 200 gallons of herbicide in right-of-ways in various locations throughout the city.

Utility Locating (Blue Stakes)

- Received and completed 83 locate requests requiring 43 hours.

Training

- Weekly in-house safety training

Miscellaneous

- Maintenance on equipment and public works facilities.
- Saturday Dumpsters.
- Staff and department meetings.
- Moving and organizing equipment and parts (Inventory)
- Performed inspections of active projects.
- Assist in obtaining GPS points to update Ivins City mapping.
- Repaired one irrigation leak on Ivins Irrigation System at 50 N 100 W (broken two-inch PVC)

