DEPARTMENT OF PUBLIC WORKS
SUMMARY OF OPERATIONS
NOVEMBER 2015

Water System

- Completed 20 utility work orders
- Installed 7 new ¾" service meters this month
- Changed out 21 faulty registers/ERTs/service meters.
- Completed meter reading monthly vault and tank inspections and water samples
- Repaired service leak at 385 W Meridian Drive
- Replaced two main line valves at Praya Dr/Cordero Dr intersection after major water leak identified complete corrosion of the bonnet bolts. The Department is concerned that all valves in this 14 year old subdivision are subject the same corrosion and imminent failure.

Sewer System

- Weekly lift station maintenance

Street Maintenance

- Used approximately four tons of road base to repair streets due to water leaks.
- Applied 14,760 lbs of crack seal material to prepare for Slurry project in the spring.
- Logged 18 hours of sweeping streets covering 46 lane miles.
- Staff started prepping subgrade on the 200 W 200 S sidewalk project.

Storm Drain

- Cleaned storm grates and removed sediment and debris from culvert inlets.
- Weekly Public Works Facility Storm Water Inspections.

Vegetation Control

- Cleared weeds and trash from right of ways in various locations throughout the city.
- Trimmed bushes and tree branches in various locations throughout the city.

Utility Locating (Blue Stakes)

- Received and completed 171 locate requests requiring 25 hours.

Training

- Weekly in-house safety training

Miscellaneous

- Maintenance on equipment and public works facilities.
- Saturday Dumpsters.
- Staff and department meetings.
- Moving and organizing equipment and parts (Inventory)
- Assist in obtaining GPS points to update Ivins City mapping
- Assist parks with burials as needed.

Fleet Maintenance

- Assist with maintenance as needed.

